

MXTW*** is the version with CO2 software of the MPXPRO control for refrigeration units. Allows the safe management of low superheat via supervision (Very Low SuperHeat) using as interface: CAREL IROOUG*300 terminal (3-digit display and 4 keys); CAREL IROOUG*300 display (3-digit display). Temperature display: -50T150 °C, operating temperature: -10T60°C, humidity: < 80% non-condensing. **Att.:** to enable and use the VLSH functionality, coordination from Boss (with dedicated plug-in) or BMS is essential. The MXTW** functions are the same of MX30** and use the same hardware. Differences are highlighted here with a note (#) VLSH.

Table 1: display

Icon	Function	Description	Meaning of icons/Status of function		
			ON	OFF	Flashing
	COMPRESSOR	Status of compressor/solenoid valve output	Active	Inactive	Activation delayed by protection times
	FAN	Status of fan output	Active	Inactive	Activation disabled externally or due to procedure in progress
	DEFROST	Status of defrost output	Active	Inactive	Activation disabled externally or due to procedure in progress
	AUX (auxiliar)	Status of auxiliary output	Active	Inactive	
	ALARM	Alarm status during normal operation or from digital input	Pre-activation of an external delayed digital alarm	No active alarm	Active alarms
	CLOCK	RTC option, at start-up comes on to indicate the option is available	Control in night-time operation	Control in daytime operation	Clock alarm
	LIGHT	Status of local or network light output	Active	Inactive	
	SERVICE	General service signals	On the master indicates that the parameters are being sent to the slaves	No malfunction	Malfunction (System error). Contact service.
	HACCP	HACCP alarm signal	Function enabled	Function disabled	HACCP alarm active, HA/HF signal on display
	CONTIN. CYCLE	Status of continuous cycle function.	Operating	Not operating	Call pending

Table 2: MPXPRO keypad and main functions - The user terminal (code IROOUG*300) is an interface that in addition to the display functions, allows access to the MPXPRO parameter configuration menu using the keypad next to the display. Depending on the connection and the configuration of the local network, the entire network can be managed from just one point.

Category	Function	Front keypad functions		Display / Notes
		Button	Duration	
SET POINT	Temperature set point	Set		Set point value flashing
		Set		Modify the set point
ACCESS TO PARAMETERS	Type F parameters (frequent)	Pr	5 s	Save set point and return to initial display
		Pr & Set	5 s	The first type F parameter is displayed
		Pr & Set	5 s	
ACCESS TO PARAMETERS	Type C or A parameters (configuration)	Pr & Set		Enter password (default C=22, A=33)
		Set		Confirm the password, the first type C (or A) parameter is displayed
ACCESS TO PARAMETERS	Exit	Pr & Set	5 s	
		Set		
NETWORK FUNCTIONS (master only)	Copy parameters from Master to Slave	Pr & Set	5 s	Enter password (default 66)
		Set		For further info see the MPXPRO manual
NETWORK FUNCTIONS (master only)	Display unit network status from Master (Virtual Console)	Pr & Set		Select Slave unit (for further info see the MPXPRO manual "Display unit network status from Master")
		Set		
DEFAULT	Reset default parameters	Pr	at start-up	

Table 3: main functions available on the keypad

Category	Function	Front keypad functions		Display / Notes
		Button	Duration	
DEFROST	Local defrost	Pr	5 s	dFb: start defrost call; dFe: end defrost call
		Pr	5 s	dFb: start defrost call; dFe: end defrost call.
DEFROST	Multiplexed defrost from master only	Pr	5 s	
		Pr	5 s	
AUXILIARIES	Continuous cycle	Pr	5 s	ccb: start continuous cycle call; cce: end continuous cycle call
		Pr	5 s	
AUXILIARIES	AUX output	Pr	5 s	
		Pr	5 s	
ALARMS	Alarm log	Pr	5 s	Enter password (default 44)
		Pr	5 s	for further info see the MPXPRO manual, par. "Alarm log"
ALARMS	Manual alarm reset	Pr	5 s	rES: indicates the alarms with manual reset have been reset.
		Pr	5 s	
ALARMS	Mute buzzer and disable alarm relay (1)	Pr	5 s	
		Pr	5 s	
HACCP	HACCP menu	Pr	for further info see the MPXPRO manual, par. "HACCP alarms"	

Important: to permanently save all the changed values and exit the parameter menu, press PRG/mute for 5 s; to exit without saving the values (exit by TIMEOUT) do not press any button for at least 60 s

Nota: (!) disables the slave offline signals for one minute.

Table 4: Function parameters - function, with VLSH (#) variables

Cod.: code of the parameter as shown on the display
 Parameter: parameter name and possible values
 Type: parameter type C (basic applications, PW 22), F (frequent), A (advanced applications, pw 33), NV (not visible from the terminal, supervision only)
 U.M.: unit of measure - Min, Max o Def: Minimum, maximum, default
 "A" parameters are shown in bold - Note: write the new values down
 N.B.: (#) MPXPRO not standard parameters or specific for VLSH

Code	Parameter	U.M.	Type	Def.	Min	Max
Temperature probe management parameters (/Pro)						
/2	Analogue probe measurement stability	-	A	4	1	15
/4	Virtual probe composition: 0: outlet probe Sm; 100: intake probe Sr	%	C	0	0	100
/5	Temperature unit of measure; 0: °C; 1: °F; 2: °F/psig	-	A	0	0	1
/6	Display decimal point (0: enabled; 1: disabled)	-	A	0	0	1
rHS	Makeup of glass temperature sensor estimate 0: outlet probe Sm; 100: intake probe Sr	%	NV	20	0	100
/t	Display alarms/signals on remote terminal 0: disabled; 1: enabled	-	A	0	0	1
/t1	Display on user terminal: 0: disabled; 1: 7: S1...S7; 8: 11 serial probe S8...S11; 12: Control probe (Sreg); 13: Virtual probe (Sv); 14: Set point;	-	C	12	0	14
/t2	Display on remote terminal (See /t1)	-	A	12	0	14
/P1 (#)	Select type of probe, Group 1 (S1, S2, S3); 0: NTC Standard with Range -50T90°C; 1: n.d.-RESERVED; 2: PT1000 Stand. Range -50T150 °C; 3: n.d.-RESERVED	-	A	0	0	3
/P2	Select type of probe, Group 2 (S4, S5) (See /P1)	-	A	0	0	3
/P3	Select type of probe, Group 3 (S6); 0: ...; 3: (See /P1); 4: Ratiometric probe 0...5V	-	A	0	0	4
/P4	Select type of probe, Group 4 (S7); 0: ...; 4: (See /P3); 5: Input 0...10V; 6: Input 4...20 mA	-	A	0	0	6
/P5	Select type of probe, Group 5: serial probe (S8...S11)	-	A	0	0	15
/FA	Assign outlet temperature probe (Sm)	-	C	1	0	11
/Fb	0: Function disabled; 1: 7: S1 to S7; 8: 11 serial probe S8 to S11	-	C	2	0	11
/Fc	Assign defrost temperature probe (Sd) (See /FA)	-	C	3	0	11
/Fd	Assign intake temperature probe (Sv) (See /FA)	-	C	3	0	11
/Fe	Assign superheated gas temp. probe (Tgs) (See /FA)	-	A	0	0	11
/Ff	Assign saturated evap. press. temp. probe (Ptu/Teu) (See /FA)	-	A	0	0	11
/Fg	Assign defrost temperature probe 2 (Sd2) (See /FA)	-	A	0	0	11
/Fh	Assign auxiliary temperature probe 1 (Saux1) (See /FA)	-	A	0	0	11
/Fi	Assign auxiliary temperature probe 2 (Saux2) (See /FA)	-	A	0	0	11
/Fj	Assign room temperature probe (SA) (See /FA)	-	A	0	0	11
/Fl	Assign room humidity probe (SU) (See /FA)	-	A	0	0	11
/Fm	Assign glass temperature probe (Svt) (See /FA)	-	A	0	0	11
/Fn	Assign dewpoint value (Sdp) to a serial probe 0: disabled function; 1: 4: serial probe S8...S11	-	A	0	0	4
/c1	Probe 1 calibration	°C/°F	F	0	-20	20
/c2	Probe 2 calibration	°C/°F	F	0	-20	20
/c3	Probe 3 calibration	°C/°F	F	0	-20	20
/c4	Probe 4 calibration	°C/°F	F	0	-20	20
/c5	Probe 5 calibration	°C/°F	F	0	-20	20
/c6	Probe 6 calibration	°C/°F	F	0	-20	20
/c7	Probe 7 calibration	°C/°F	F	0	-20	20
/U6	Maximum value of sensor 6 - Note A: 160 if /S=0; 999 if /S=1	°C/°F, barg, U.R.%	A	9.3	/L6	note A
/L6	Minimum value of sensor 6 - Note B: -20 if /S=0; -90 if /S=1	°C/°F, barg, U.R.%	A	-1.0	note B	/U6
/U7	Maximum value of sensor 7 - Note A: 160 if /S=0; 999 if /S=1	°C/°F, barg, U.R.%	A	9.3	/L7	note A
/L7	Minimum value of sensor 7 - Note B: -20 if /S=0; -90 if /S=1	°C/°F, barg, U.R.%	A	-1.0	note B	/U7
Temperature control parameters (CtL)						
OFF	ON/OFF - 0: ON; 1: OFF	-	A	0	0	1
S1	Set point	°C/°F	F	50	r1	r2
S2	Intake probe set point with "Double thermostat"	°C/°F	A	50	r1	r2
rd	Set point differential St	°C/°F	F	2	0.1	20
rd2	Set point S2 differential with "Double thermostat" 0.0: function disabled	°C/°F	F	0	0	20
r1	Minimum Set point	°C/°F	A	-50	-50	r2
r2	Maximum Set point	°C/°F	A	50	r1	50
r3	Enable end defrost signal by timeout 0: disabled; 1: enabled	-	A	0	0	1
r4	Automatic night-time set point variation	°C/°F	C	0	-50	50
r6	Probe for night-time control 0: virtual probe (Sv); intake probe (Sr)	-	C	0	0	1
ro	Control offset in the event of probe error	°C/°F	A	0.0	0.0	20

Code	Parameter	U.M.	Type	Def.	Min	Max
r7	Master solenoid valve configuration 0: local valve; 1: network valve (connected to Master)	-	C	0	0	1
r5u	Delay in closing suction valve during normal control	sec	C	0	0	999
rMu	Min. opening % for liquid refrigerant flow control	%	A	0	0	100
ClT	Maximum time for Clean mode	min	A	0	0	999
Stt	Maximum time for Stand-by mode	min	A	0	0	240
Compressor management parameters (CMP)						
c0	Compressor and fan start delay on power-up	min	A	0	0	240
c1	Minimum time between successive starts	min	A	0	0	15
c2	Minimum off time	min	A	0	0	15
c3	Minimum on time	min	A	0	0	15
c4	ON time for operation in duty setting (Toff = 15 minutes fixed) 0: compressor/valve always OFF; 100: compressor/valve always ON	min	A	0	0	100
cc	Duration of operation in continuous cycle	hours	A	1	0	15
c6	Low temperature alarm bypass time after continuous cycle	min	A	60	0	240
c7	Defrost priority over continuous cycle (0: no; 1: yes)	-	A	0	0	1
Defrost management parameters (dEF)						
d0	Select type of defrost: 0: heater by temperature; 1: hot gas by temperature; 2: heater by time; 3: hot gas by time; 4: heater by time w/ temp. control; 5: multiplexed hot gas by temperature; 6: multiplexed hot gas by time	-	C	0	0	6
d2	End defrost synchronised by Master - 0: not synchronised; 1: synchronised	-	A	1	0	1
d3	Master doesn't send network defrost command; 0: disabled; 1: enabled Slaves ignore network defrost command; 0: disabled; 1: enabled	-	A	0	0	1
d1	Maximum interval between consecutive defrosts	hour	C	8	0	240
d11	End defrost temperature (read by Sd)	°C/°F	F	8.0	-50.0	50.0
d12	End defrost temperature (read by Sd2)	°C/°F	F	8.0	-50.0	50.0
dP1	Maximum defrost duration	min	F	45	1	240
dP2	Maximum defrost duration on secondary evaporator	min	A	45	1	240
d4	Defrost on start-up 0: disabled; 1: enabled (Master: network defrost; Slave: local defrost)	-	A	0	0	1
d5	Defrost delay on start-up (if d4=1): delay disabled	min	A	0	0	240
d6	Display on terminal during defrost 0: temperature alternating with 'dFE'; 1: display frozen; 2: 'dFE'	-	C	1	0	2
dd	Dripping time after defrosting (fans off): 0: no dripping	min	A	2	0	15
d7	Skip defrost 0: disabled; 1: enabled	-	A	0	0	1
d8	High temperature alarm bypass time after defrost	min	C	30	1	240
d9	Defrost priority over compressor protection times 0: protection times respected; 1: protection times ignored	-	A	1	0	1
Sd1	Defrost probe	°C/°F	F	-	-	-
Sd2	Secondary evaporator defrost probe	°C/°F	F	-	-	-
dC	Time base for defrost: 0: 'd' in hours, 'dP1', 'dP2' and 'ddP' in minutes 1: 'd' in minutes, 'dP1', 'dP2' and 'ddP' in seconds	-	A	0	0	1
d10	Defrost time in "Running time" 0: function disabled	min	A	0	0	240
d11	Temperature threshold for "running time" defrost	°C/°F	A	-30	-50	50
d12	Pressure probe alarm management during defrost 0: probe error disabled, updating after supervisor enabled 1: probe error disabled, updating after supervisor enabled 2: errore sonda disabilitato, updating after supervisor disabled 3: probe error enabled, updating after supervisor disabled	-	A	0	0	3
dS1	Compressor off time for "sequential stop" defrost: 0: function disabled	min	A	0	0	45
dS2	Compressor operating time for "sequential stop" defrost	min	A	120	0	240
ddt	Additional end defrost temperature delta for "power defrost"	°C/°F	A	0.0	-20.0	20.0
ddP	Additional maximum end defrost time delta for "power defrost"	min	A	0	0	60
dN	Nominal duration of the defrost for "skip defrost"	%	A	75	0	100
d15	Number of daily defrosts (td1)	-	C	0	0	14
d25	Number of daily defrosts (td2)	-	C	0	0	14
dH1	Pump down duration (0: pump down disabled)	s	A	0	0	999
dHG	Type of multiplexed hot gas defrost: 0: equalising valve normally closed; 1: equalising valve normally open	-	A	0	0	1
dSb	Valve position during defrost: 0: valve position as required by defrost type; 1: valve forced close; 2 -100: opening percentage	%	A	0	0	100
Alarm management parameters (ALM)						
AA	Assign probe for high (AH) and low (AL) temperature alarm: 1: Control; 2: Virtual; 3: Outlet; 4: Defrost; 5: Intake; 6: Superheat gas; 7: Saturated evap; 8: Auxiliary defrost; 9: Auxiliary; 10: Auxiliary 2; 11: Room temperature; 12: Room humidity; 13: Glass temperature; 14: dew point	-	F	1	1	14
AA2	Assign probe for high (AH2) and low (AL2) temperature alarm (see AA)	-	A	5	1	14
A0	Reset high and low temperature alarm differential	°C/°F	F	2.0	0.1	20.0
A1	Alarm thresholds (AL, AH) relative to set point (St) or absolute 0: relative; 1: absolute	-	F	0	0	1
A2	Alarm thresholds (AL2, AH2) relative to set point (S2) or absolute 0: relative; 1: absolute	-	A	0	0	1
AL	Low temperature alarm threshold	°C/°F	F	4.0	-50.0	50.0
AH	High temperature alarm threshold	°C/°F	F	10.0	-50.0	50.0
AL2	Low temperature alarm threshold 2	°C/°F	A	0.0	-50.0	50.0
AH2	High temperature alarm threshold 2	°C/°F	A	0.0	-50.0	50.0
Ad	Delay time for high and low temperature alarms	min	F	120	0	240
Ad2	Delay time for high and low temperature alarms (AH2, AL2)	min	F	120	0	240
A4	Configure function of digital input D11 on S4: 0: input not active; 1: immediate external alarm; 2: delayed external alarm; 3: enable defrost; 4: start defrost; 5: door switch with comp. and fans OFF; 6: remote ON/OFF; 7: curtain switch; 8: start/stop continuous cycle; 9: input status monitoring; 10: retaining digital input; 11: Stand-by mode switch; 12: Clean mode switch; 13: working parameters set change; 14: door switch with comp. and fans ON; 15: defrost according to DI status	-	C	0	0	15
A5	Configure function of digital input D12 on S5 (see A4)	-	C	0	0	15
A6	Configure solenoid/compressor control during external alarm (immediate or delayed) with 15 min. fixed OFF period 0: always OFF; 100: always ON	min	A	0	0	100
A7	Delay time for delayed external alarm	min	C	0	0	240
A8	Configure function of virtual digital input (see A4)	-	A	0	0	8
A9	Digital input propagated from Master to Slave (on Master only): 0: da supervisor; 1: DI1; 2: DI2; 3: DI3; 4: DI4; 5: DI5	-	A	0	0	5
A10	Configure function of digital input D13 on S6 (see A4)	-	C	0	0	15
A11	Configure function of digital input D14 on S7 (see A4)	-	C	0	0	15
A12	Configure function of digital input D15 (see A4)	-	C	0	0	15
Ar	Send alarms from Slave to Master: 0: disabled; 1: enabled	-	A	1	0	1
A13	Enable hot gas safety procedure for Slave offline: 0: disabled; 1: enabled	-	A	0	0	1
Add	High temperature alarm bypass time after door open	min	C	30	1	240
Evaporator fan management parameters (FAn)						
F0	Configure fan management: 0: fans always on; 1: controlled based on Sd-Sv (or Sd-Sm in double thermostat); 2: controlled based on Sd.	-	C	0	0	2
F1	Fan temperature control threshold (only if F0=1 or 2)	°C/°F	F	-5.		